



---

## CERTIFICATE OF APPROVAL

### No CF 5513

---

This is to certify that, in accordance with  
TS00 General Requirements for Certification of Fire Protection Products  
The undermentioned products of

## COOPERS FIRE LTD

Ignis House, Houghton Avenue,  
Waterlooville,  
Hampshire,  
England,  
PO7 3DU  
Tel: 02392 454405

Have been assessed against the requirements of the Technical Schedule(s)  
denoted below and are approved for use subject to the conditions  
appended hereto:

---

#### CERTIFIED PRODUCT

FireMaster® Plus<sup>2</sup> Active Fire  
Curtain

#### TECHNICAL SCHEDULE

TS 30 – Industrial Type Fire  
Resisting Doorsets

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan  
Certification Manager

Issued: 20<sup>th</sup> March 2017  
Re-issued: 21<sup>st</sup> December 2021  
Valid to: 20<sup>th</sup> December 2026





## CERTIFICATE No CF 5513

### COOPERS FIRE LTD

#### FireMaster® Plus<sup>2</sup> Active Fire Curtain

1. This approval relates to the use of FireMaster® Plus<sup>2</sup> Active Fire Curtains in providing a fire resistance performance of up to 180 minutes integrity performance, as defined in BS EN 1634-1: 2008 The scope of approval is summarised as follows:

#### Continuous Barriers / Single Roller

Integrity Performance (mins)	Maximum Height (metres)	Maximum Width (metres)
120	7	7
	6.2	7.8
180	4	7

All dimensions quoted in the above tables are internally between guides and from underside of head box to floor level (i.e. visible fabric dimensions)

2. The product is CERTIFIRE approved on the basis of:
- i) Initial type testing.
  - ii) An appraisal against TS30.
  - iii) Inspection and surveillance of factory production control
3. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturers' name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.
4. The FireMaster® Plus<sup>2</sup> Active Fire Curtains are approved for installation into concrete, masonry or timber stud partitions having a fire performance no less than that required for the fire curtain. Typical installation details are provided in the datasheet.
5. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.