

Declaration of Performance

1. **Unique identification code of the product type:** FireMaster® A1 Closed Concertina
2. **Intended use:** Fire/smoke compartmentation and on escape routes
3. **Name and address of manufacturer:** Coopers Fire Limited, Ignis House, Houghton Avenue, Waterlooville, Hampshire. PO7 3DU, UK
4. **Standards:** BS 8524-1:2013
5. **Fire Resistance:** 240 minutes integrity and 30 minutes radiation performance to BS EN 1634-1:2014 (BS EN 1363-1:2016 & BS EN 1363-2:1999) Smoke Leakage with $<3\text{m}^3/\text{h}/\text{m}$, to BS EN 1634-3 using calculations from BS 8524-1:2013 annex F.
6. **IFC Certification number:** IFCC/1256
7. **Approved body:** Name: IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire, HP27 9AH, United Kingdom

Signed for and on behalf of the manufacturer by:

David Cerquella



Managing Director

Date: 9th October 2023